



- Legend**
- Proposed Landtake
 - Original Proposed Land Boundary
 - Proposed Incoming Raw Sewage Main
 - Proposed Outgoing Final Effluent Main
 - Proposed Chamber
 - Proposed Tank
 - Proposed Building
 - Proposed Sludge Plant
 - Proposed Handstanding and Plant
 - Proposed Access (within site perimeter)

- Notes:**
1. This drawing is not to be scaled. Figured dimensions only to be taken.
 2. This drawing is for indicative use only. The Process type and arrangement shown requires confirmation by outline design.
 3. 38kV Power line passes through the proposed land boundary. It is assumed that the power line to be re-routed around site boundary.
 4. All earthworks shall be at a maximum slope of 1V : 2H.
 5. All tanks shall be covered with GRP clam shell covers.
 6. All drawings to be checked by the Contractor on Site.
 7. Engineer to be informed by the Contractor of any discrepancies before any work commences.
 8. All levels shown relate to Ordnance Survey datum at Malin Head, the geographic coordinate system is to Irish Transverse Mercator (ITM).

Copyright © Ordnance Survey Ireland. Licence number 3/3/34/Irish Water. Service Layer- © OpenStreetMap (and) contributors, CC-BY-SA



0	06/06/2018	Final	SM	RG	SK	CoK
Rev.	Date	Purpose of revision	Drawn	Check'd	Rev'd	App'd



Client
 UISCE
 IREANN - IRISH WATER

Project
 Greater Dublin Drainage Project

Drawing Title
 Figure 4.5 - Zonal Arrangement of the Proposed Wastewater Treatment Plant

Drawing Status
Final

Scale @A3 **1:4,500** DO NOT SCALE

Jacobs No. 32102902

Filepath
 V:\GIS\MapInfo\MapInfo\Report\Chapter\Figures\Fig4_5_ZonalArrangement_ofthe_ProposedWastewaterTreatmentPlant.mxd

Drawing No. 32102902-EIAR-405

This drawing is not to be used in whole in or part other than for the intended purpose and project as defined on this drawing. Refer to the contract for full terms and conditions.

